

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHIECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1180118

Product: Halogen free conduit

Type: LSOH 40/34

Rating: diameter 40 mm

Ordering firm: TIÚ-PLAST a.s.
Práce 657, 277 11 Neratovice, Czech Republic

Manufacturer: TIÚ-PLAST a.s.
Práce 657, 277 11 Neratovice, Czech Republic

Factories: TIÚ-PLAST a.s.
Práce 657, 277 11 Neratovice, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 800504-01/01 of: 20.02.2018

A sample of the product was found to be in conformity with:
ČSN EN 60332-1-2:05+A1:16+A11:17,
ČSN EN 60332-1-1:05+A1:16

Other data:

The validity of the certificate is limited to: 28.02.2021

26.02.2018

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



800504-01